

Multivibrator
MV



Input	Data type	Description	Range
On	BOOL	Start	
T	INT	Pulse period, ms	> 0
Output	**Data type**	**Description**	**Range**
Q	BOOL	Output	

Function

If the input On is 1, the pulses with the period T are generated. The pulse duration is equal to the pause between each pulse, i. e. T/2.



Devices	PR110, PR114, PR200
Version	1.0
Last modification	27.02.2015